LightGraphix Creative Lighting Solutions

INSTRUCTION LEAFLET

This product should be installed by a qualified electrician in accordance with all current, local legislation. For the UK, the current edition of the IEE Wiring Regulations and European Standard IEC 60364

LD43DR-C1



Deep Recessed LED Recessed Uplighter

SPECIFICATION

LED surfaced mounted luminaires are class III for Safety Extra Low Voltage DC supply. The product should only be used with a supplied or LightGraphix approved 350mA, 500mA or 700mA constant current driver.


Suitable for mounting on normally flammable surfaces.

Lamp: C1 LED Engine.

This fitting is IP66 rated. Lumen Maintenance: L90B5 at 90,000hrs.


LD43DR - C1			
Product & LED Output Code	Power Output	Max Ambient	Energy Class
LD43DR-C1-350	350mA 1.2W	-20° to 50°	E
LD43DR-C1-500	500mA 1.7W	-20° to 50°	E
LD43DR-C1-700	700mA 2.4W	-20° to 50°	F







Spring Clip



SEE CONSTANT CURRENT WIRING SHEET FOR IN SERIES WIRING DIAGRAM

Do not power up until fitting is wired correctly! Constant current LEDs must be wired in series, polarity is critical. Please refer to specified driver sheet for details on the minimum and maximum number of LEDs per circuit.

CORF COLOUR & POLARITY Colour of Cable Red Black Polarity +

END OF LIFE

This fitting contains a replaceable (LED only) light source, that must be replaced by a professional. If the product has come to the end of its life or is in need of repair please contact LightGraphix or your preferred recyling scheme



IMPORTANT

Make sure that all cables and connections are securely connected before switching on the power. Failing to do this can lead to failure of the LEDs and/or Clean with soft damp cloth the driver. If the LEDs do not work upon power up, turn off the power source immediately and check the polarity of the wiring. Any attempt made to open LED: Please contact LightGraphix up and/or modify the luminaire will invalidate the manufacturers warranty. The external cable of this luminaire cannot be replaced; if the cable is damaged 0-ring replacement part numbers: Outer 0-ring 17.0010. the luminaire shall be destroyed. This is inclusive of but not limited to removal of the LightGraphix product label or removal of any parts from the main body of the product including bezels, electrical components and factory fitted fixing methods (unless otherwise stated in these instructions). Luminaire CONNECTION should be wired no further than 30 meters away from a SELV constant current LED driver (based on a 1mm squared cross sectional cable). Forward voltage of luminaire is 18VDC, if wired in series UOUT of LED driver and luminaire circuit should not exceed 60VDC. Terminal block not included. Installation -No. of Positions: 1Way must be performed by a qualified person. For connections made in dry environments 2 x Wago 221-2411 or connections with similar specifications are -Rated Voltage: 450V recommended. For damp or wet environments a connector of the same electrical specification but with a suitable IP rating should be used. The fitting -Rated Current: 32A guarantees a minimum static load resistance of 5kN. The rated maximum surface temperature is less than 100°C.

MAINTENANCE


-Wire Connection Method: Clamp -Wire Size (stranded): 18 - 14AWG

LightGraphix reserve the right to change specifications without notice. This leaflet should be issued and retained by the end user

Factory Address: LightGraphix, 20 Bourne Road Ind. Park, Crayford, Kent, DA1 4BZ

/GS44-45

45% reduced output glare shield



INSTALLATION

1. Bore clearance holes to suit dimensions below.

2. Wire the luminaire to a specified driver.

NOTE: Connections in wet environments. Make IP68 connection to stop water travelling up the cables into the fittings! Refer to IP connection sheet for further details.

3. When using /480 Fixing Sleeve, bond in sleeve into cut-out with one of the recommended adhesives; Rotabond 2000, 3M 4200 Marine Adhesive or Simson MSR Construction Adhesive. The same process can be applied to the luminaire itself.

4. When using /SC Spring Clips, squeeze mounting springs into body with finger and thumb

5. Push in the luminaire into the cut-out hole until flush with surface.

6. When fitted with a /GS Glare Shield, orientate the fitting with a grippy pair of gloves, so that the shield is horizontal to the lit surface.